



THE VERTICAL SEPARATION FROM NEUTRAL CONDUCTORS SHALL BE INCREASED SO THAT THE LOWEST POINT OF THE NEUTRAL CONDUCTOR (IN THE SPAN OR AT THE CROSSING) WILL BE AT LEAST 30 INCHES ABOVE THE CABLE ATTACHMENT LEVEL (LINE OF SIGHT) AS ILLUSTRATED ABOVE.

AERIAL CABLE SEPARATION REQUIREMENTS

				DATE	DEPARTMENT OF TRANSPORTATION STATE OF GEORGIA	
				REVISION	CONSTRUCTION DETAIL	
					UTILITY CLEARANCE	
				BY	NOVEMBER 2020 NO SCALE	NUMBER TS-07